



## Declaration of Performance DoP

No. 001-CPR-2016

1. Product identification code: ExiLED M ST LED 22m LP 1t
2. Type, batch or serial number: Part number:  
290280
3. Intended use: Emergency light on fire alarm loop, installed in buildings
4. Name and contact address of the manufacturer: Honeywell Life Safety AS  
P.O. Box 3514  
N-3007 Drammen  
Norway  
e-mail: [fire.safety@honeywell.com](mailto:fire.safety@honeywell.com)
5. Name and contact address of authorized representative: Not applicable
6. System or systems of assessment and verification of constancy of performance of the construction product: System 1
7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:  
Name and identification number of the notified body: Nemko AS, no. 0470  
has performed type testing in accordance with system 1 and has issued following certificate of constancy of performance: 0470-CPR-0034
8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued: Not applicable



by Honeywell

9. Declared performance:

Essential characteristics	Performance	Harmonized technical specification
Performance under fire conditions	Passed	EN 54-17:2005 Art.: 5.2 EN 54-18:2005 Art.: 5.1.4
Operational reliability	Passed	EN 54-17:2005 Art.: 4 EN 54-18:2005 Art.: 5.1.4
Durability of operational reliability: Temperature resistance	Passed	EN 54-17:2005 Art.: 5.4, 5.5 EN 54-18:2005 Art.: 5.3, 5.4
Durability of operational reliability: Vibration resistance	Passed	EN 54-17:2005 Art.: 5.9 to 5.12 EN 54-18:2005 Art.: 5.8 to 5.11
Durability of operational reliability: Humidity resistance	Passed	EN 54-17:2005 Art.: 5.6, 5.7 EN 54-18:2005 Art.: 5.5, 5.6
Durability of operational reliability: Corrosion resistance	Passed	EN 54-17:2005 Art.: 5.8 EN 54-18:2005 Art.: 5.7
Durability of operational reliability: Electrical stability	Passed	EN 54-17:2005 Art.: 5.3, 5.13 EN 54-18:2005 Art.: 5.2, 5.12

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Sven-Ingve Rasmussen, R&D Manager

Name and position

Drammen, 21.04.2016

Place and date of issue

Signature

NORWAY / Honeywell Life Safety AS

Lierstranda Industriområde, P.O. Box 3514, 3007 Drammen, Norway

E-mail: [fire.safety@honeywell.com](mailto:fire.safety@honeywell.com)

Phone: +47 32 24 48 00

Internet: [www.eltek-fs.com](http://www.eltek-fs.com)