



## Declaration of Performance DoP

No. 001-CPR-2019

1. Product identification code: Delta Compact Quad+
2. Type, batch or serial number: Part number:  
271801.1  
271801.4  
271801.21  
271802.1  
271802.4  
271802.21  
271802.101  
271803.1  
271803.21  
271804.18  
271806.21
3. Intended use: Fire detection and fire alarm systems installed in buildings
4. Name and contact address of the manufacturer: Honeywell Life Safety AS  
P.O. Box 3514  
N-3007 Drammen  
Norway  
e-mail: [fire.safety@honeywell.com](mailto:fire.safety@honeywell.com)
5. Name and contact address of authorized representative: Not applicable
6. System or systems of assessment and verification of constancy of performance of the construction product: System 1
7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:  
Name and identification number of the notified body: Nemko AS, no. 0470  
has performed type testing in accordance with system 1 and has issued following certificate of constancy of performance: 0470-CPR-0040
8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued: Not applicable



9. Declared performance:

Essential characteristics	Performance	Harmonized technical specification
Performance under fire conditions	Passed	EN 54-2:1997 + A1:2006 Art.: 4, 5, 7
Response delay (response time to fire)	Passed	EN 54-2:1997 + A1:2006 Art.: 7.1, 7.7, 7.11, 7.12
Operational reliability	Passed	EN 54-2:1997 + A1:2006 Art.: 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14
Durability of operational reliability, Temperature resistance	Passed	EN 54-2:1997 + A1:2006 Art.: 15.4
Durability of operational reliability, Vibration resistance	Passed	EN 54-2:1997 + A1:2006 Art.: 15.6, 15.7, 15.15
Durability of operational reliability, Electrical stability	Passed	EN 54-2:1997 + A1:2006 Art.: 15.8 to 15.13
Performance of power supply	Passed	EN 54-4:1997 + A2:2006 Art.: 4, 5, 6
Operational reliability	Passed	EN 54-4:1997 + A2:2006 Art.: 4, 5, 6, 7, 8
Durability of operational reliability, Temperature resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.5
Durability of operational reliability, Vibration resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.7, 9.8, 9.15
Durability of operational reliability, Electrical stability	Passed	EN 54-4:1997 + A2:2006 Art.: 9.9 to 9.13
Durability of operational reliability, Humidity resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.6, 9.14
Durability of operational reliability, Humidity resistance	Passed	EN 54-2:1997 + A1:2006 Art.: 15.5, 15.14

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Sven-Ingve Rasmussen, Interim R&D Leader HSF Nordics

Name and position

Drammen, 19.12.2019

Place and date of issue

Signature

NORWAY / Honeywell Life Safety AS

Lierstranda Industriområde, P.O. Box 3514, 3007 Drammen, Norway

Phone: +47 32 24 48 00

E-mail: [fire.safety@honeywell.com](mailto:fire.safety@honeywell.com)

Internet: [www.eltek-fs.com](http://www.eltek-fs.com)