

# DECLARATION OF PERFORMANCE



**Manufacturer:** European Safety Systems Ltd.  
Impress House, Mansell Road, Acton  
London, W3 7QH, UK

**Equipment Type:** BExS110D (24V DC), BExS120D (24V DC)

## Intended Use

Fire Safety (Fire Detection and Fire Alarm Systems – Alarm Devices – Sounders, buildings)

## System of Assessment and Verification of Constancy of Performance

2+

## Notified Body

**Notified Body for EC type Examination and Factory  
Production Control:**

VdS Schadensverhütung GmbH  
Notified Body No.: 0786  
Amsterdamer Str 172-174, 50735 Köln, Germany

**EC-type Examination Certificate:**

0786-CPD-20225

## Declared Performance

Essential Characteristics	Performance	Standard
Performance under fire condition	Pass	EN 54-3:2001 / A1:2002
Operational reliability	Pass	
Durability of operational reliability, temperature resistance	Pass	
Durability of operational reliability, corrosion resistance	Pass	
Durability of operational reliability, shock and vibration resistance	Pass	
Durability of operational reliability, electrical stability	Pass	
Durability of operational reliability, resistance to ingress	Pass	

The performance of the product identified above is in conformity with the declared performance. This declaration of performance is issued under the sole responsibility of the manufacturer identified above.

A handwritten signature in black ink, appearing to read 'Martin Streetz'.

**Martin Streetz**  
Quality Assurance Manager

**Date and Place of Issue:** London, 05/06/2013  
**Document No:** DP-007-Issue\_A