

Procedure:	EC DECLARATION OF PERFORMANCE		
Document No:	DOP0002	Issue No:	1
Form:	KAC826-01	Date:	28 <sup>th</sup> June 2013
Approved By:	William Nock (QA Manager)		

**According to EU Construction Products Regulation No. 305/2011**

1. Unique Product Identification Code(s): WCP1, WCP2, WCP3, WCP4

2. Type Number(s):
- WCP1A-R[abc][d][e]-[fghi]-[jk]
  - WCP1B-R[abc][d][e]-[fghi]-[jk]
  - WCP2A-R[abc][d][e]-[fghi]-[jk]
  - WCP2B-R[abc][d][e]-[fghi]-[jk]
  - WCP3A-R[abc][d][e]-[fghi]-[jk]
  - WCP4A-R[abc][d][e]-[fghi]-[jk]

Where :

- [abc] indicates electrical configuration
- [d] indicates mounting type: S = surface
- [e] indicates element type: F = Flexible; G = Glass
- [fghi] indicates customer reference
- [jk] indicates other information

Description: Manual Call Point for outdoor use

3. Intended Use: Fire detection and fire alarm systems installed in and around buildings

4. Manufacturer: KAC Alarm Company Limited  
KAC House, Thornhill Road,  
North Moons Moat,  
Redditch, B98 9ND, UK

5. Trading Company: KAC Alarm Company Limited  
KAC House, Thornhill Road,  
North Moons Moat,  
Redditch, B98 9ND, UK

6. System of assessment: System 1

7. Notified Body: LPCB – BRE  
Bucknalls Lane  
Garston  
Watford  
WD25 9XX

Notified Body Number: 0832

EC Certificate Number(s)  
WCP1A – 0832-CPD-0654  
WCP1B – 0832-CPD-0655  
WCP2A – 0832-CPD-0656  
WCP2B – 0832-CPD-0658  
WCP3A – 0832-CPD-0659  
WCP4A – 0832-CPD-0660

8. European Technical Assessment Reference: Not Applicable

9. Declared Performance:

Procedure:	EC DECLARATION OF PERFORMANCE		
Document No:	DOP0002	Issue No:	1
Form:	KAC826-01	Date:	28 <sup>th</sup> June 2013
Approved By:	William Nock (QA Manager)		

EN 54-11: (2006) Fire Detection and Fire Alarm Systems – Manual Call Points		
Clause	Description	Performance
4.1.	Compliance	Pass
4.2.	Marking and data	Pass
4.3.	Frangible element	Pass
4.4.	Indicators for alarm condition	Pass
4.5.	Reset facility	Pass
4.6.	Test facility	Pass
4.7.	Construction and design	Pass – Type A
4.8.	Additional requirements for software controlled manual call points	n/a
5.1.	General	Pass
5.2.	Operational performance	Pass
5.3.	Function	Pass
5.4.	Test facility	Pass
5.5.	Reliability	Pass
5.6.	Variation of supply	Pass
5.7.	Dry heat (operational)	Pass
5.8.	Dry heat (endurance)	Pass
5.9.	Cold (operational)	Pass
5.10.	Damp heat cyclic (operational)	Pass
5.11.	Damp heat cyclic (endurance)	Pass
5.12.	Damp heat steady state (endurance)	Pass
5.13.	Sulphur dioxide (SO <sub>2</sub> ) corrosion (endurance)	Pass
5.14.	Shock (operational)	Pass
5.15.	Impact (operational)	Pass
5.16.	Vibration, sinusoidal (operational)	Pass
5.17.	Vibration, sinusoidal (endurance)	Pass
5.18.	Electromagnetic compatibility (EMC) (operational)	Pass
5.19.	Enclosure protection	Pass

We hereby declare that the product identified above meets the requirements of the following EC Directives and therefore qualify for free movement within markets comprising the European Union (EU) and the European Economic Area (EEA):

<b>• ATEX Directive, 94/9/EC</b>	
Conforms to:	
Notified Body:	
Notified Body Number:	
EC Certificate Number	
<b>• Marine Equipment Directive 96/98/EC as amended, last amended by Directive 2009/26/EC</b>	
Conforms to:	60092-504:2001
Notified Body:	LPCB
Notified Body Number:	0832
Module B certificate number:	0832-MED-1011
Module D certificate number:	0832-MED-1012
Technical construction file retained at:	BRE

Procedure:	EC DECLARATION OF PERFORMANCE		
Document No:	DOP0002	Issue No:	1
Form:	KAC826-01	Date:	28 <sup>th</sup> June 2013
Approved By:	William Nock (QA Manager)		

**Conforms to:**


- Low Voltage Directive (LVD) 2006/95/EC
- EMC Directive 2004/108/EC
- REACH - Regulation (EC) No 1907/2006
- ROHS - Directive 2011/65/EU
- WEEE - Directive 2012/19/EU

**Approved Accessories: -**

C Hinged Cover

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.  
This declaration of performance is issued under the sole responsibility of the manufacture identified below.

For and on behalf of  
KAC Alarm Company.

Signature 

William Nock (**Quality Manager**)

KAC Alarm Company Limited  
KAC House,  
Thornhill Road,  
North Moons Moat,  
Redditch,  
B98 9ND,  
UK

Date: 28 June 2013